

F11' TEEN ROPE FERRY ROAD



WATERFORD, CT 06385-2886

**ADDENDA #3
Notice to Bidders
Bid#23-111 Town of Waterford Cell Tower Sites HVAC Replacement**

January 9, 2023


The purpose of this addendum is to provide information to Bidders.

Bidders are advised as follows:

1. The specifications in the plans have a section for balancing/TABB work, is this required for this project?

Answer: No TABB is required for these self-contained units.

Feel free to contact me should you require any additional information.



Rawle Dummett
Purchasing Agent
Town of Waterford