

ADDENDUM #1

Issue Date: 1/4/24

Project Name: Clark Lane Chiller Replacement

Project No.: 2019141.02

GENERAL:

Modifications described herein as Addendum items supersede specific parts of the Contract Documents for the above-named project. All bids and the construction contract shall be based on the inclusion of these modifications.

CLARIFICATION TO DRAWINGS

Clarifications: Contractor states Item #1 below.

Item #1 “Chiller spec (ME-100) is calling for the chiller to have factory mounted pumping package, yet underneath the chiller schedule is the pump schedule calling for the pumps to be by Taco.” Please clarify intent.

CLARIFICATION

ITEM 1: Response, Chiller pumping package is provided by Trane. Pumps and all accessories are packaged by Trane, manufactured by Taco.

CLARIFICATION TO PERMIT FEES

Clarifications: Contractor states item#2 below.

Item #2 “Are permit fees waived for this project?”

CLARIFICATION

ITEM 2: Response, No.

END OF ADDENDUM

T:\2019\2019141.02\Addenda\ADDENDUM.#1.docx.docx
