

From: Michael Ott <ottm@summerhillcivilengineers.com>
Sent: Wednesday, May 8, 2024 8:54 AM
To: Maureen Fitzgerald
Cc: Mark Fader; Dwayne Xenelis; Russell E. Learned, AIA
Subject: CC Application No. C-24-03 - Williams School Athletic Complex
Attachments: 23-43 Civil Permit Drawings Submission Revised 5-1-24.pdf

CAUTION: This email originated from outside of the organization.

Do not click links or open attachments unless you recognize the sender's email address and know the content is safe.

Good morning Maureen.

Below is a list of the revisions made to the permit drawings set:

- Revised the proposed storm drainage system to separate it from the existing system
- Revised the grading associated with the stormwater basin
- Added erosion control blankets to the slopes along the east and west sides of the building
- Added a revised inland wetland non-encroachment boundary
- Added a split rail fence
- Added an inland wetland buffer plantings zone
- Added Sheet C1.1 Orthophotograph Vicinity Plan sheet to the drawings set
- Added a Precast Concrete Area Drain detail to Sheet C3.1 Details
- Revised the Typical Stormwater Basin Section on Sheet C3.1 Details
- Added a Marker Post Installation detail to Sheet C3.2 Details
- Added an Erosion Control Blankets for Slopes detail to Sheet C3.3 Details

I've attached the full revised permit drawings set here.

-Mike

Michael J. Ott, P.E., L.S.

Summer Hill Civil Engineers & Land Surveyors, P.C.
60 Wall Street | P.O. Box 708
Madison, Connecticut 06443-0708
Office: (203) 245-0722
Cell: (860) 662-1137

