

CLA Engineers, Inc.

Civil • Structural • Survey

317 MAIN STREET

NORWICH, CT 06360

(860) 886-1966

(860) 886-9165 FAX

SIEVE ANALYSIS

Date: 8/22/2022

Project: Indigo Land Design

CLA Project #: 6449


Source: Great Neck Test Pits


Material: On-site material (Test Pits)

Specification: N/A

Sample Designation: Test Pit #4

Sieve Size	% Passing
3/4 in	51.8
1/4 in	49.4
#4	48.5
#10	44.6
#20	37.2
#40	27.1
#60	19.5
#100	13.6
#200	6.8


Thomas Cummings *26 AUG 22*
PE No. 9606



[illegible]